

INSTALLATION TERMS & CONDITIONS

(February 21st, 2019 until further notice)

ROLEC
EV



STANDARD INSTALLATION SPECIFICATION

- The chosen WallPod charge point
- A maximum cable run of 10 metres from source of supply (consumer unit) to charge point
- The property's consumer unit must include sufficient RCD protection and have a spare empty slot to allow for the installation of an electrical protection device at source
- Cable to be surface mounted – clipped direct
- No ground works
- The charger to be installed at the back of the garage (inside the equipotential zone) connected to the household earthing arrangement, which should comply with current regulations and wiring standards
- The property is within 75 mile (150 mile round trip) of an approved installer or their satellite installer
- The homeowner must comply with all current OLEV Domestic Scheme Ts & Cs (see OLEV website for Terms and Conditions)

ADDITIONAL COSTS (TO BE NEGOTIATED PRIOR TO INSTALLATION BETWEEN THE HOME OWNER AND INSTALLER)

The following information provides a guideline of work that is considered to be beyond the standard installation specification:

- Cable runs exceeding 10 metres (chargeable per metre thereafter)
- The necessity to install a mini consumer unit c/w overload and fault current protection due to:
 - a) the property's consumer unit having insufficient capacity/protection for the charge point circuit
 - b) the homeowner wishing to have an independent charge point circuit protection from the home's consumer unit
- Any additional mechanical protection required for the cabling - i.e. trunking, conduit, etc.
- Any cable chasing requested by the homeowner
- Any ground works requested by the homeowner
- The necessity to introduce an alternative earthing system, i.e. an electrode/inspection chamber
- The property being further away than 75 mile (150 mile round trip) from an approved installer or their satellite installer's base
- Any additional or unusual works requested by the homeowner in order for the install to take place, i.e. gas and water pipe bonding, equipment clearing, plumbing work, etc.

PLEASE NOTE


- All charge points issued under the new OLEV scheme will contain a new set of unique serial numbers
- The new serial number will need to be quoted on the OLEV paperwork in order to validate your claim
- Removal of the serial number from the unit will invalidate the warranty on the product
- These serial numbers are only available on the authorised product (detailed anywhere the product code is followed by the '/OLEV' initials)
- All installations must comply with current IET Wiring Regulations

On Behalf of Rolec EV,

Adam Browning

Technical Support Executive

Images are for marketing purposes only and are not contractual © 2019



Head office contact:
t: +44 (0) 1205 724754
f: +44 (0) 1205 724876
rolec@rolecserv.co.uk

Rolec Services Ltd
Ralphs Lane, Frampton West
Boston, Lincolnshire
UK. PE20 1QU

 @RolecEV
www.rolecserv.com